

NATIONAL TYPE EVALUATION PROGRAM

Certificate of Conformance for Weighing and Measuring Devices

For: Crane Scale Digital Electronic Model: MSI-4260C, MSI-4260M, MSI-4260 IS, MSI-6360 and MSI-9600 n<sub>max</sub>: 5000 Capacity: see standard features and options section Accuracy Class: III / III L **Submitted By:** 

Rice Lake Weighing Systems 230 West Coleman Street Rice Lake, WI 54868 Tel: 715-234-9171 Fax: 715-234-6967 Contact: Brad Bowers Email: <u>bbowers@ricelake.com</u> Web site: <u>www.ricelake.com</u>

Standard Features and Options				
Model	Capacity	d	n <sub>max</sub>	Accuracy Class
MSI-4260C, MSI-4260M	500 – 2000 lb	0.2, 0.5, 1 lb	2500	III
MSI-4260 IS	(250 - 1000  kg)	(0.1, 0.2, 0.5 kg)		
MSI-4260C, MSI-4260M	5000 – 70000 lb	1,2,5,10,20 lb	5000	III L
MSI-4260 IS	(2500 – 35000 kg)	(0.5, 1, 2, 5, 10 kg)		
MSI-6360, MSI-9600	500 – 2000 lb	0.2, 0.5, 1 lb	2500	III
	(250 - 1000  kg)	(0.1, 0.2, 0.5 kg)		
MSI-6360, MSI-9600	5000 - 70000 lb	1,2,5,10,20 lb	5000	III L
	(2500 – 35000 kg)	(0.5, 1, 2, 5, 10 kg)		

IS-Intrinsically safe, M-Marine, C-Third generation

- Automatic Zero Tracking (AZT)
- Semi-Automatic Tare (Push Button)
- Unit Conversion (lb / kg)
- DC Power / Battery, 4.5 to 14.5 VDC (10.5 to 14 VDC for MSI-4260 IS)
- Remotely Calibrated or Configured (except MSI-4260 IS)
- RS-232:/ USB (except MSI-4260 IS)
- Remote customer display (except MSI-4260 IS)

- Semi-Automatic Zero (Push Button)
- Integral Display (except MSI-6360)
- Power Saving Feature (Sleep Mode & Auto Shut Off)
- Liquid Crystal Display / Light Emitting Diode Display
- Ethernet/Wireless (except MSI-4260 IS)
- Category 1 physical seal

This device was evaluated under the National Type Evaluation Program and was found to comply with the applicable technical requirements of *Handbook 44:* Specifications, Tolerances and Other Technical Requirements for Weighing and Measuring Devices. Evaluation results and device characteristics necessary for inspection and use in commerce are on the following pages. \*Editorial changes, not affecting the type or metrological content, corrected this certificate.

thequique

Mahesh Albuquerque Chair, NCWM, Inc.

Ivan Hankins Chair, NTEP Committee Issued: October 14, 2022

## 1135 M Street, Suite 110 / Lincoln, Nebraska 68508

The National Conference on Weights and Measures (NCWM) does not approve, recommend, or endorse any proprietary product or material, either as a single item or as a class or group. Results shall not be used in advertising or sales promotion to indicate explicit or implicit endorsement of the product or material by the NCWM.



## **Rice Lake Weighing Systems**

Crane Scale / MSI Series

Application: General purpose Crane Scale

**Identification:** A metal identification plate is riveted to the face of the scale above the display.

Sealing: The scale is sealed with a lead-and-wire security seal on the side of the scale housing.

<u>Test Conditions</u>: This Certificate supersedes Certificate of Conformance number 19-122 and is issued to add the models MSI-6360 and MSI-9600 to this certificate. Both models are added without additional testing. Previous test conditions are listed below for reference.

<u>Certificate of Conformance 19-122</u>: The emphasis of the evaluation was on the device design, operation, and marking requirements. A Model MSI-4260 IS and a Model MSI-4260C were submitted for evaluation. Several increasing/ decreasing load and creep tests were performed. The device was tested over a temperature range of -10 C to 40 C (14 F to 104 F). The MSI-4260 IS was tested at 10.5 VDC and 15.4 VDC and the MSI-4260C was tested at 4.2 VDC to 16 VDC. Previous test conditions are listed on CC88-098 & CC89-090.

Evaluated By: M. Kelley (OH) 19-122; J. Gibson (OH) 16-122A1

**Type Evaluation Criteria Used:** Handbook 44 Specifications, Tolerances, and Other Technical Requirements for Weighing and Measuring Devices, 2022 Edition. NCWM Publication 14: Weighing Devices, 2022 Edition.

**<u>Conclusion</u>**: The results of the evaluation and information provided by the manufacturer indicate the device complies with applicable requirements.

Information Reviewed By: D. Flocken (NCWM) 19-122, 19-122A1

## Example(s) of Device:

Model: MSI-4260 IS & MSI-4260C

Model: MSI-4260M





Rice Lake Weighing Systems Crane Scale / MSI Series

Model: MSI- 6360

Model: MSI-9600

