



Australian Government
Department of Industry,
Science and Resources

**National
Measurement
Institute**

36 Bradfield Road, West Lindfield NSW 2070

Supplementary Certificate of Approval

NMI S836

Issued by the Chief Metrologist under Regulation 60
of the
National Measurement Regulations 1999

This is to certify that an approval for use for trade has been granted in respect of the instruments herein described.

Rice Lake Model 682-2A Digital Indicator

submitted by Rice Lake Weighing Systems
 230 W Coleman St
 Rice Lake
 WI 54868
 USA

NOTE: This Certificate relates to the suitability of the pattern of the instrument for use for trade only in respect of its metrological characteristics. This Certificate does not constitute or imply any guarantee of compliance by the manufacturer or any other person with any requirements regarding safety.

This approval has been granted with reference to document NMI R 76, *Non-automatic weighing instruments, Parts 1 and 2*, dated October 2015.

This approval is subject to review at the decision of the Chief Metrologist in accordance with the conditions specified in the document NMI P 106.

DOCUMENT HISTORY

Rev	Reason/Details	Date
0	Pattern and variants 1 to 4 approved – certificate issued	20/02/24
1	Variants 2 & 3 cancelled (separate approval) – certificate issued	04/03/24

CONDITIONS OF APPROVAL

General

Instruments purporting to comply with this approval shall be marked with approval number 'NMI S836' and only by persons authorised by the submittor.

Instruments incorporating a component purporting to comply with this approval shall be marked 'NMI S836' in addition to the approval number of the instrument, and only by persons authorised by the submittor.

It is the submittor's responsibility to ensure that all instruments marked with this approval number are constructed as described in the documentation lodged with the National Measurement Institute (NMI) and with the relevant Certificate of Approval and Technical Schedule. Failure to comply with this Condition may attract penalties under Section 19B of the National Measurement Act and may result in cancellation or withdrawal of the approval, in accordance with document NMI P 106.

Auxiliary devices used with this instrument shall comply with the requirements of General Supplementary Certificate of Approval No S1/0B.

The values of the performance criteria (maximum number of scale intervals etc.) applicable to an instrument incorporating the pattern approved herein shall be within the limits specified herein and in any approval documentation for the other components.

Signed by a person authorised by the Chief Metrologist to exercise their powers under Regulation 60 of the *National Measurement Regulations 1999*.



Darryl Hines
Manager
Policy and Regulatory
Services

TECHNICAL SCHEDULE No S836

1. Description of Pattern

approved on 20/02/24

A Rice Lake model 682-2A digital mass indicator (Figure 1 and Table 1) which may be configured to form part of:

- A class III weighing instrument with a single weighing range of up to 10000 verification scale intervals; or
- A class III weighing instrument with a single weighing range of up to 1000 verification scale intervals; or
- A class III multi-interval weighing instrument with up to three partial weighing ranges (each with its own verification scale interval) in which case it is approved for use with up to 10 000 verification scale intervals per partial weighing range; or
- A class III multi-interval weighing instrument with up to three partial weighing ranges (each with its own verification scale interval) in which case it is approved for use with up to 1000 verification scale intervals per partial weighing range; or
- A class III multiple range weighing instrument with up to three weighing ranges, in which case it is approved for use with up to 10 000 verification scale intervals per weighing range; or
- A class III multiple range weighing instrument with up to three weighing ranges, in which case it is approved for use with up to 1000 verification scale intervals per weighing range.

The changeover between weighing ranges is automatic.

The instrument has a stainless steel enclosure with an LCD display for display of the weight value and for alphanumeric information and/or menu.

Instruments may be fitted with output sockets (output interfacing capability) for the connection of auxiliary and/or peripheral devices (see clause 1.8 below).

TABLE 1 – Specifications

Maximum number of verification scale intervals	10 000 (class III) 1000 (class III)
Minimum sensitivity	1 μV / scale interval
Excitation voltage	10 V DC
Maximum excitation current	250 mA
Fraction of maximum permissible error	$p_i = 0.5$
Minimum load cell impedance	43 Ω
Maximum load cell impedance	1050 Ω
Measuring range minimum voltage	0 mV
Measuring range maximum voltage	30 mV
Maximum tare range	-100% Max
Operating temperature range	-10°C to +40°C
Load cell connection	4-wire or 6-wire shielded
Maximum value of load cell cable length per wire cross section (*)	1320 m/mm ² (6-wire only)

(*) Additional connection cable between indicator and load cell or load cell junction box. In case a 4-wire connection is used, the load cells are connected directly without a junction box or lengthening the load cell(s) cable.

This approval does not include the use of the indicator as an automatic weighing instrument, unless specifically mentioned in a certificate of approval for such an instrument.

1.1 Zero

A zero-tracking device may be fitted.

The initial zero-setting device has a nominal range of not more than 20% of the maximum capacity of the instrument.

The instrument has a semi-automatic zero-setting device with a nominal range of not more than 4% of the maximum capacity of the instrument.

1.2 Tare

A semi-automatic subtractive taring device of up to the maximum capacity of the instrument may be fitted.

A pre-set taring device (keyboard-entered and/or stored) of up to the maximum capacity (or of up to the Max_1 for multi-interval instruments) may also be fitted.

1.3 Alternative Units

Use of units other than tonnes (t) or kilograms (kg) or grams (g) is not approved for trade use.

1.4 Linearisation Facility

Instruments are fitted with a linearisation correction facility having four correction points.

1.5 Display Check

A display check is initiated whenever power is applied.

1.6 Power Supply

The instrument operates from mains AC power (110-240 V AC, 50/60 Hz).

1.7 Additional Features

Instruments may be fitted with additional functions including setpoint/batching, weigh-in/weigh-out and accumulators. The additional functions (other than the indications of measured mass, i.e. gross, tare, net, totals, displayed either on the indicator or on an auxiliary or peripheral device) are not approved for trade use.

Note: In particular circumstances (e.g. in regard to weighbridge or public weighbridge operation), Trade Measurement legislation or other NMI Certificates of Approval may impose requirements in regard to specific features, methods of operation, or records to be provided (and in what form).

Certain features of this instrument are able to be configured by the installer or user. Whilst NMI believes that an acceptable configuration can be achieved for typical basic modes of operation, it may also be possible for the instrument to be configured to produce unacceptable configurations, and use of some configurations may be inappropriate in different situations. It is the responsibility of the installer and user to ensure that the configuration is acceptable and meets relevant requirements for any particular situation.

1.8 Interfaces

The indicator may be fitted with interfaces for the connection of auxiliary and/or peripheral devices. Any interfaces shall comply with clause 5.3.6 of document NMI R76 (the basic intent of which is that it shall not be possible to alter weighing results via the interfaces).

Any measurement data output from the instrument or its interfaces shall only be used for trade in compliance with NMI General Supplementary Certificate of Approval No S1/0B (in particular in regard to the data and its format).

Indications other than the indications of measured mass (i.e. gross, tare, net, totals) displayed either on the indicator or on an auxiliary or peripheral device, are not for trade use.

Instruments may be fitted with RS-232, RS485, Ethernet, Bluetooth, WiFi, USB, digital inputs/outputs and analogue outputs.

1.9 Verification Provision

Provision is made for the application of a verification mark.

1.10 Descriptive Markings and Notices

Instruments carry the following markings:

Manufacturer's mark, or name written in full	Rice Lake Weighing Systems
Indication of accuracy class	 or 
Maximum capacity (for each range)	<i>Max</i> kg #1
Minimum capacity (for each range)	<i>Min</i> kg #1
Verification scale interval (for each range)	<i>e</i> = kg #1
Serial number of the instrument
Pattern approval mark for the indicator	NMI S836
Pattern approval mark for other components #2

#1 These markings are shown near the display of the result.

#2 May be located separately from the other markings.

In addition, instruments not greater than 100 kg capacity carry a notice stating NOT TO BE USED FOR TRADING DIRECT WITH THE PUBLIC, or similar wording.

Notes:

For multi-interval instruments the markings shall be as above, with the exception that the 'Maximum capacity' and 'Verification scale interval' shall be marked for both interval ranges, e.g. as follows:

Maximum capacity	<i>Max</i>/..... /..... kg
Verification scale interval	<i>e</i> =/..... /..... kg

For multiple range instruments, the maximum capacity, minimum capacity and verification scale interval for each range shall be marked, with an indication of the range to which they apply, e.g.

Range (*)	R1	R2	R3
<i>Max</i> kg kg kg
<i>Min</i> kg kg kg
<i>e =</i> kg kg kg

1.11 Software

The legally relevant software is designated 2.xx.xx, where 'xx.xx' represents the identification of non-legally relevant software.

The instructions for accessing the legally relevant version numbers are as follows (starting from the normal weighing mode):

- Press the 'MENU' key. The flow chat and its description for the Audit Menu is displayed.
- Press the 'TARE' key to enter the Audit Menu.
- Press the 'TARE' key again. The legally relevant version is displayed.

1.12 Sealing Provision

Provision is made for the calibration and configuration to be sealed by setting the audit jumper (J24) on the mainboard to an OFF position, and then preventing access to the setup switch within the instrument housing by means of using a 'lead and wire' type seal with drilled screws (Figure 4a), or placing destructible labels over an access hole to the setup switch and the opposite sides of a join in the instrument housing as shown in Figure 4b.

Alternatively the indicator is sealed by recording the audit trail counter on verification.

Access to allow changing of set-up parameters including calibration parameters must be protected by a passcode.

The indicator automatically increments a configuration and/or calibration value (audit trail number) each time the indicator is re-configured and/or calibrated.

The value(s) of these counters may be recorded on a destructible adhesive label attached to the instrument (e.g. as CONFIG x, CAL y).

Any subsequent alteration to the calibration or configuration will be evident as the recorded values and the current counter values will differ.

The instructions for accessing the configuration and calibration audit trail are as follows (starting from the normal weighing mode):

- Press the 'MENU' key. The flow chat and its description for the Audit Menu is displayed.
- Press the 'TARE' key to enter the Audit Menu.
- Press the 'PRINT' key once. The 'Calibration Counter' value is displayed; or
- Press the 'PRINT' key twice. The 'Configuration Counter' value is displayed.
- Press the 'Menu' key to return to the normal weighing mode.

2. Description of Variant 1 **approved on 20/02/24**

The Rice Lake model 682-2D which is similar to the pattern but operating from 9 – 36 V DC power source (not suitable for a road vehicle power supply).

3. Description of Variant 2 **approved on 20/02/24**
cancelled on 04/03/24

The Rice Lake model 680-2A (Figure 2) which is similar to the pattern but having an LED display for display of the weight value and may be configured to form part of:

- A class  weighing instrument with a single weighing range of up to 10000 verification scale intervals; or
- A class  weighing instrument with a single weighing range of up to 1000 verification scale intervals.

3.1 Interfaces

Instruments may be fitted with RS-232, RS485, Ethernet, USB, digital inputs/outputs and analogue outputs.

3.2 Software

The legally relevant software is designated v1.xx.xx, where 'xx.xx' represents the identification of non-legally relevant software.

The instructions for accessing the legally relevant version numbers are as follows (starting from the normal weighing mode):

- Press the 'MENU' key.
- Press the 'TARE' key twice. The legally relevant version is displayed.

4. Description of Variant 3 **approved on 20/02/24**
cancelled on 04/03/24

The Rice Lake model 680-2D which is similar to variant 2 but operating from 9 – 36 V DC power source (not suitable for a road vehicle power supply).

5. Description of Variant 4 **approved on 20/02/24**

The pattern or variants model number may include an additional '-E' suffix which represents an external Ethernet RJ45 connector on the back of instrument housing (Figure 3).

TEST PROCEDURE No S836

Instruments should be tested in accordance with any relevant tests specified in the National Instrument Test Procedures.

Maximum Permissible Errors

The maximum permissible errors are specified in Schedule 1 of the *National Trade Measurement Regulations 2009*.

For multi-interval and multiple range instruments with verification scale intervals of $e_1, e_2 \dots$, apply e_1 for zero adjustment, and maximum permissible errors apply $e_1, e_2 \dots$, as applicable for the load.

FIGURE S836 – 1




Rice Lake Model 682 Digital Indicator (Pattern)

FIGURE S836 – 2




Rice Lake Model 680 Digital Indicator (Variant 2)

FIGURE S836 – 3



External RJ45 Connector (Variant 4)


FIGURE S836 – 4



Sealing (Model 682)


Sealing (Model 680)

(a) Lead and Wire Type of Sealing



Access Hole (Model 682)

Access Hole (Model 680)



(b) Adhesive Labels Sealing

Typical Sealing

~ End of Document ~