



Member of the FM Global Group

FM Approvals
1151 Boston Providence Turnpike
P.O. Box 9102 Norwood, MA 02062 USA
T: 781 762 4300 F: 781-762-9375 www.fmaprovals.com

CERTIFICATE OF COMPLIANCE

HAZARDOUS (CLASSIFIED) LOCATION ELECTRICAL EQUIPMENT

This certificate is issued for the following equipment:

RLPWM15, RLPWM15HE, RL50210SS, RL72010MH. Load Cells

IS / I,II,III / 1 / ABCDEFG — 66147; Entity*; NI / I / 2 / ABCD; S / II,III / 2 / FG

*Refer to Dwg. 66147 for entity parameters.

Equipment Ratings:

Intrinsically Safe for use in Class I, II and III, Division 1, Groups A, B, C, D, E, F and G; Temperature class T4 when installed in accordance with Entity requirements and control drawing 66147; Nonincendive for use in Class I, Division 2, Groups A, B, C and D; Suitable for use in Class II and III, Division 2, Groups F and G Hazardous (Classified) Locations

FM Approved for:

Rice Lake Weighing Systems
Rice Lake, WI 54868
USA



This certifies that the equipment described has been found to comply with the following Approval Standards and other documents:

Class 3600	1998
Class 3610	2010
Class 3810	1989
Class 3611	2004


Original Project ID: 3044623

Approval Granted: June 11, 2012


Subsequent Revision Reports / Date Approval Amended

Report Number	Date	Report Number	Date
120710	July 11, 2012		
3046983	Aug 7th, 2012		

FM Approvals LLC



Timothy Adam
Technical Team Manager



Date