

Net Fill with Setpoint Key Example

ProAction PCEE - [Net Fill with Setpoint Key]

File Communications Tools View Help

Step List

Step #	Name
1	Enter Setpoint Value
2	Finished with Entry
3	Wait for Start Key Press
4	Check for Container/Tare
5	Net Fill Setpoint
6	Delay to Display Net

New Step
Rename Step
Remove Step
Move Step Up
Move Step Down

☒ Enabled ☐ Pausable

Conditions "True" Actions "False" Actions Pause Actions

Conditions

- User Key Compare

Net Fill with Setpoint Key

STEP 1: Enter Setpoint Value (Enabled, Not Pausable)

CONDITIONS

User Key Compare, Key Number: 2
Comment: Setpoint Key Pressed?

TRUE ACTIONS

Get Database Record, Slot: 0, Index: 2, MoveType: FIRST
Comment: Find First Record in the Prompts Database
DB Prompt, Slot: 0, Index: 2, Field: 5
Comment: Put "Enter Setpoint" on the Display
User Get Compare, Condition: 23, Compare Type: WEIGHT
Comment: Get current Setpoint Value to Display
User Get, Capture Type: REAL
Comment: Get new Setpoint Value and Store in Real Variable
Deactivate Step, Step Number: 1
Comment: Deactivate this step when it is completed.
Activate Step, Step Number: 2
Comment: Activate the next step.

FALSE ACTIONS

PAUSE ACTIONS

STEP 2: Finished with Entry (Not Enabled, Not Pausable)

CONDITIONS

User Entry, Comment: Wait for User Entry of Setpoint Value

TRUE ACTIONS

User Set Compare, Condition: 23, Compare Type: WEIGHT
Comment: Set New Setpoint Value
Deactivate Step, Step Number: 2
Comment: Deactivate this step when it is completed.
Activate Step, Step Number: 3
Comment: Activate the next step.
Activate Step, Step Number: 1
Comment:

FALSE ACTIONS

PAUSE ACTIONS

STEP 3: Wait for Start Key Press (Enabled, Not Pausable)

CONDITIONS

User Key Compare, Key Number: 1
Comment: Wait for Start Key Press (1st Softkey)

TRUE ACTIONS

Deactivate Step, Step Number: 3
Comment: Deactivate this step when it is completed.
Activate Step, Step Number: 4

Net Fill with Setpoint Key

Comment: Activate the next step.

FALSE ACTIONS

Clear Tare, Scale Number: SCALE1

Comment: Remove any Previous Tare Value

Get Database Record, Slot: 0, Index: 2, MoveType: FIRST

Comment: Find the First Record in the Prompts Database

DB Prompt, Slot: 0, Index: 2, Field: 1

Comment: Put "Press Start Key" on the Display

PAUSE ACTIONS

STEP 4: Check for Container/Tare (Not Enabled, Not Pausable)

CONDITIONS

Weight Compare, Source: SCALE1, Value: 10, Mode: GROSS, Trip: INBAND, Band Value: 2,

Preact Mode: OFF, Preact Value: 0

Comment: Check for a Container [10 Lbs (+ / - 2 Lbs)] on the Scale

Motion Compare, Source: SCALE1, Trip: STANDSTILL

Comment: Check that the Scale is also at Stand still

TRUE ACTIONS

Tare Scale, Scale Number: SCALE1

Comment: Tare off Container / Switch to Net Mode

Deactivate Step, Step Number: 4

Comment: Deactivate this step when it is completed.

Activate Step, Step Number: 5

Comment: Activate the next step.

FALSE ACTIONS

DB Prompt, Slot: 0, Index: 2, Field: 2

Comment: Display "Put Container On" message

PAUSE ACTIONS

STEP 5: Net Fill Setpoint (Not Enabled, Not Pausable)

CONDITIONS

Weight Compare, Source: SCALE1, Value: 150, Mode: NET, Trip: HIGHER, Band Value: 0,

Preact Mode: OFF, Preact Value: 0

Comment: Fill to a Net Value of 150 Lbs

TRUE ACTIONS

Digital Output, Slot: 0, Relay Number: 1, State: OFF

Comment: Turn off the 1st Digital Output above 150 Lbs

DB Prompt, Slot: 0, Index: 2, Field: 4

Comment: Display "Done" message

Start Timer, Timer Number: 1, Duration: 3000

Comment: Display Net Weight for 3 Seconds

Deactivate Step, Step Number: 5

Comment: Deactivate this step when it is completed.

Activate Step, Step Number: 6

Comment: Activate the next step.

Net Fill with Setpoint Key

FALSE ACTIONS

Digital Output, Slot: 0, Relay Number: 1, State: ON

Comment: Turn on the 1st Digital Output below 150 Lbs

DB Prompt, Slot: 0, Index: 2, Field: 3

Comment: Display "Filling in Progress" message

PAUSE ACTIONS

STEP 6: Delay to Display Net (Not Enabled, Not Pausable)

CONDITIONS

Timer Compare, Timer Number: 1, Target State: STOPPED

Comment: 3 Second Delay before Looping Back

TRUE ACTIONS

Deactivate Step, Step Number: 6

Comment: Deactivate this step when it is completed.

Activate Step, Step Number: 3

Comment: Loop Back to Step 1 (Start)

FALSE ACTIONS

PAUSE ACTIONS