


CERTIFICATE OF CONFORMITY



- HAZARDOUS (CLASSIFIED) LOCATION ELECTRICAL EQUIPMENT PER US REQUIREMENTS**
- Certificate No:** FM17US0119X
- Equipment:** Models RL70000B, RL75223, RL8C2P1, RL39523, RL70000SS, RL20000FLS, RL20000SS, RL8C2P1SST.
(Type Reference and Name) Load Cells
- Name of Listing Company:** Rice Lake Weighing Systems
- Address of Listing Company:** 230 W Coleman St, Rice Lake, Wisconsin 54868 USA
- The examination and test results are recorded in confidential report number:
3062444 dated 8th September 2017
- FM Approvals LLC, certifies that the equipment described has been found to comply with the following Approval standards and other documents:
FM Class 3600:2018, FM Class 3610:2018, FM Class 3611:2016, FM Class 3810:2005, ANSI/ISA 60079-0:2013, ANSI/ISA 60079-11:2014, ANSI/ISA 61010-1:2012
- If the sign 'X' is placed after the certificate number, it indicates that the equipment is subject to specific conditions of use specified in the schedule to this certificate.
- This certificate relates to the design, examination and testing of the products specified herein. The FM Approvals surveillance audit program has further determined that the manufacturing processes and quality control procedures in place are satisfactory to manufacture the product as examined, tested and Approved.
- Equipment Ratings:**
Intrinsically Safe for Class I, II, III Division 1, Groups A, B, C, D, E, F and G per Dwg 66020; Non-Incendive for Class I, Division 2, Groups A, B, C and D per Dwg 66020, Suitable for use in Class II and III, Division 2, Groups F and G per Dwg 66020 in hazardous (classified) locations with a T4 rating and an ambient temperature rating of -25°C to +40°C

Certificate issued by:



J.E. Marquedant
VP, Manager - Electrical Systems

3 September 2021

Date

To verify the availability of the Approved product, please refer to www.approvalguide.com

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

FM Approvals LLC. 1151 Boston-Providence Turnpike, Norwood, MA 02062 USA
T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: information@fmapprovals.com www.fmapprovals.com

SCHEDULE



US Certificate Of Conformity No: FM17US0119X

11. The marking of the equipment shall include:

IS Class I, II, III, Division 1, Groups *, C, D, E, F and G; T4; Ta = -25°C to +40°C; Entity. Per Dwg 66020
NI Class I, Division 2, Groups A, B, C, and D; T4 Ta = -25°C to +40°C; NIFW; Per Dwg 66020;
Suitable Class II, III, Division 2, Groups F and G; T4 Ta = -25°C to +40°C; NIFW; Per Dwg 66020;
*see specific conditions of use

12. **Description of Equipment:**

General – The Load cells produce an output signal proportional to the applied weight force. The conversion of load measurements to electrical signals is made through the use of strain gauges. These are arranged in a balanced bridge configuration so that the deflection of the strain gauges causes a change in their resistance and unbalances the bridge circuit. For a given input voltage, the output voltage of the bridge will vary with the applied load or pressure.

Enclosure:

The circuitry of the Load Cell is encapsulated within the housing.

Ratings:

The Load Cells operate at 16 VDC max. The load cells are rated for use in an ambient temperature range of -25°C to +40°C.

Models RL70000B, RL75223, RL8C2P1, RL39523, RL70000SS, RL20000FLS, RL20000SS, RL8C2P1SST. Load Cell

Entity/NIFW Parameters:

Positive Excitation Barrier:

$V_{Max} = +12\text{ V}$, $I_{Max} = 179\text{ mA}$, $P_{Max} = 0.54\text{ W}$, $C_i = 0$, $L_i = 0$.

Positive Sense Barrier:

$V_{Max} = +16\text{ V}$, $I_{Max} = 50\text{ mA}$, $P_{Max} = 0.20\text{ W}$, $C_i = 0$, $L_i = 0$.

Negative Sense Barrier:

$V_{Max} = -16\text{ V}$, $I_{Max} = 50\text{ mA}$, $P_{Max} = 0.20\text{ W}$, $C_i = 0$, $L_i = 0$.

Positive Signal Barrier:

$V_{Max} = +16\text{ V}$, $I_{Max} = 50\text{ mA}$, $P_{Max} = 0.20\text{ W}$, $C_i = 0$, $L_i = 0$.

Negative Signal Barrier:

$V_{Max} = -16\text{ V}$, $I_{Max} = 50\text{ mA}$, $P_{Max} = 0.20\text{ W}$, $C_i = 0$, $L_i = 0$.

13. **Specific Conditions of Use:**

1. When only positive barriers are used, this apparatus is Intrinsically Safe for Class I, Division 1, Groups A, B, C, D, E, F, and G.

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

FM Approvals LLC. 1151 Boston-Providence Turnpike, Norwood, MA 02062 USA

T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: information@fmaprovals.com www.fmaprovals.com

SCHEDULE



US Certificate Of Conformity No: FM17US0119X

2. Under certain extreme circumstances, the non-metallic parts incorporated in the enclosure of model RL70000B and RL70000SS may generate an ignition-capable level of electrostatic charges. Therefore the equipment shall not be installed in a location where the external conditions are conducive to the build-up of electrostatic charges on such surfaces. Additionally, the equipment shall only be cleaned with a damp cloth.

14. Test and Assessment Procedure and Conditions:

This Certificate has been issued in accordance with FM Approvals US Certification Requirements.

15. Schedule Drawings

A copy of the technical documentation has been kept by FM Approvals.

16. Certificate History

Details of the supplements to this certificate are described below:

Date	Description
8 th September 2017	Original Issue. The product was Approved in 2000 under Project ID 3009433. There was no certificate issued at the time. A new Approval has been issued with Project ID 3062444 to address the following: <ul style="list-style-type: none">• Clarify Approved Models• Add FM Canadian mark to product.• Update standards.• Clean up marking information.• Updat documents.• Issue certificates of compliance.
3 rd September 2021	Supplement 1: Report Reference: – Project ID PR453582 dated 3 rd September 2021. Added Model RL20000FLS. Updated documents.

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

CERTIFICATE OF CONFORMITY

- HAZARDOUS LOCATION ELECTRICAL EQUIPMENT PER CANADIAN REQUIREMENTS**
- Certificate No:** FM17CA0061X
- Equipment:** Models RL70000B, RL75223, RL8C2P1, RL39523, RL70000SS, RL20000FLS, RL20000SS, RL8C2P1SST.
(Type Reference and Name) Load Cells
- Name of Listing Company:** Rice Lake Weighing Systems
- Address of Listing Company:** 230 W Coleman St, Rice Lake, Wisconsin 54868 USA
- The examination and test results are recorded in confidential report number:
3062444 dated 8th September 2017
- FM Approvals LLC, certifies that the equipment described has been found to comply with the following Approval standards and other documents:
CAN/CSA-C22.2 No. 60079-0:2015, CAN/CSA-C22.2 No. 60079-11:2014, CAN/CSA-C22.2 No. 213:2015, CAN/CSA-C22.2 No. 61010-1:2012.
- If the sign 'X' is placed after the certificate number, it indicates that the equipment is subject to specific conditions of use specified in the schedule to this certificate.
- This certificate relates to the design, examination and testing of the products specified herein. The FM Approvals surveillance audit program has further determined that the manufacturing processes and quality control procedures in place are satisfactory to manufacture the product as examined, tested and Approved.
- Equipment Ratings:**
Intrinsically Safe for Class I, II, III Division 1, Groups A, B, C, D, E, F and G per Control Drawing 66020; Non-Incendive for Class I, Division 2, Groups A,B,C and D per Control Drawing 66020, Dust-Ignitionproof for use in Class II and III, Division 2, Groups F and G per Control Drawing 66020 in hazardous (classified) locations with a T4 rating and an ambient temperature rating of -25°C to +40°C

Certificate issued by:



J.E. Marquedant
VP, Manager - Electrical Systems

3 September 2021
Date

To verify the availability of the Approved product, please refer to www.approvalguide.com

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

FM Approvals LLC. 1151 Boston-Providence Turnpike, Norwood, MA 02062 USA
T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: information@fmapprovals.com www.fmapprovals.com

SCHEDULE



Canadian Certificate Of Conformity No: FM17CA0061X

11. The marking of the equipment shall include:

IS Class I, II, III, Division 1, Groups *, C, D, E, F and G; T4; Ta = -25°C to +40°C; Entity; Per Dwg 66020

NI Class I, Division 2, Groups A, B, C, and D; T4 Ta = -25°C to +40°C; NIFW; Per Dwg 66020,

DIP Class II, III, Division 2, Groups F and G; T4 Ta = -25°C to +40°C; NIFW; Per Dwg 66020;

*see specific conditions of use

12. **Description of Equipment:**

General – The Load cells produce an output signal proportional to the applied weight force. The conversion of load measurements to electrical signals is made through the use of strain gauges. These are arranged in a balanced bridge configuration so that the deflection of the strain gauges causes a change in their resistance and unbalances the bridge circuit. For a given input voltage, the output voltage of the bridge will vary with the applied load or pressure.

Enclosure:

The circuitry of the Load Cell is encapsulated within the housing.

Ratings:

The Load Cells operate at 16 Vdc max. The load cells are rated for use in an ambient temperature range of -25°C to +40°C.

Models RL70000B, RL75223, RL8C2P1, RL39523, RL70000SS, RL20000FLS, RL20000SS, RL8C2P1SST. Load Cell

Entity/NIFW Parameters:

Positive Excitation Barrier:

$V_{Max} = +12\text{ V}$, $I_{Max} = 179\text{ mA}$, $P_{Max} = 0.54\text{ W}$, $C_i = 0$, $L_i = 0$.

Positive Sense Barrier:

$V_{Max} = +16\text{ V}$, $I_{Max} = 50\text{ mA}$, $P_{Max} = 0.20\text{ W}$, $C_i = 0$, $L_i = 0$.

Negative Sense Barrier:

$V_{Max} = -16\text{ V}$, $I_{Max} = 50\text{ mA}$, $P_{Max} = 0.20\text{ W}$, $C_i = 0$, $L_i = 0$.

Positive Signal Barrier:

$V_{Max} = +16\text{ V}$, $I_{Max} = 50\text{ mA}$, $P_{Max} = 0.20\text{ W}$, $C_i = 0$, $L_i = 0$.

Negative Signal Barrier:

$V_{Max} = -16\text{ V}$, $I_{Max} = 50\text{ mA}$, $P_{Max} = 0.20\text{ W}$, $C_i = 0$, $L_i = 0$.

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

FM Approvals LLC. 1151 Boston-Providence Turnpike, Norwood, MA 02062 USA

T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: information@fmapprovals.com www.fmapprovals.com

SCHEDULE



Canadian Certificate Of Conformity No: FM17CA0061X

13. Specific Conditions of Use:

1. When only positive barriers are used, this apparatus is Intrinsically Safe for Class I, Division 1, Groups A, B, C, D, E, F, and G.
2. Under certain extreme circumstances, the non-metallic parts incorporated in the enclosure of model RL70000B and RL70000SS may generate an ignition-capable level of electrostatic charges. Therefore the equipment shall not be installed in a location where the external conditions are conducive to the build-up of electrostatic charges on such surfaces. Additionally, the equipment shall only be cleaned with a damp cloth.

14. Test and Assessment Procedure and Conditions:

This Certificate has been issued in accordance with FM Approvals Canadian Certification Scheme.

15. Schedule Drawings

A copy of the technical documentation has been kept by FM Approvals.

16. Certificate History

Details of the supplements to this certificate are described below:

Date	Description
8 th September 2017	Original Issue. The product was Approved in 2000 under Project ID 3009433 for FM US only. This project added the Canadian marking and updated all the required documents.
3 rd September 2021	Supplement 1: Report Reference: – Project ID PR453582 dated 3 rd September 2021. Added Model RL20000FLS. Updated documents.

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

FM Approvals LLC. 1151 Boston-Providence Turnpike, Norwood, MA 02062 USA
T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: information@fmaprovals.com www.fmaprovals.com